

Test Report



District Level Water Analysis Laboratory, U.P. Jal Nigam
Lakhimpur Kheri

Address- Office of Executive Engineer, Construction division, U.P Jal Nigam,
Village Bhansariya Lalpur Barrier, Gola Road, Lakhimpur Kheri, 262701



Certificate No.: TC-13515

Report No:	LMP/W-/June/02	Issue Date:	12/06/2025		
Remark				Page No	1-2
Contact Person:	Vivek Rai	Address:	Kurawan, Prabhatnagar Raebareli road, Ayodhya (UP)-2244001	Mob:	9454134701

Customer Details

Innovative Minds Academy,	Kurawan, Prabhatnagar, Raebareli road, Ayodhya (UP)-2244001.

Basic details of sample

District	Ayodhya	Block	Masodha
Gram Panchayat	Kurawan	Village	Kurawan
Habitation	Kurawan	Location	School
Water Source	Borewell	Sample No.	D-1652
Quantity of Sample	1 liter	Date of Collection	10/06/2025
Receiving Date	10/06/2025	S. Collector	Sekher mishra
Sample Depositor	Sekher mishra	Sampling Method	As per IS 17614: Part 1: 2021
Analysis Start Date	11/06/2025	Analysis Completion Date:	12/06/2025

Technical Data of Analysis

	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH	7.67	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2017 (Electrometric method)
2	Turbidity NTU	0.98	1	5	IS 3025 (Pt 10):2017
3	TDS mg/L	358.4	500	2000	IS 3025 (Pt 16):2017
4	Fluoride mg/L	0.356	1	1.5	APHA 23 rd Edition 4500-F Method C (Electrode method) 2017
5	Total Hardness mg/L	232	200	600	IS 3025 (Part 21):2019
6	Total Alkalinity mg/L	240	200	600	IS 3025 (Part 23):2019
7	Chloride mg/L	27.9	250	1000	IS 3025 (Part 32):2019
8	Iron mg/L	0.098	1	1	APHA 23 rd Edition 3500-Fe Method B (Phenanthroline Method) 2017
9	Sulphate mg/L	6.562	200	400	APHA 23 rd Edition 4500-SO4 Method

					E (Turbidity Method) 2017
10	Nitrate mg/L	0.985	45	45	APHA 23 rd Edition 4500 NO3-Method B (UV Screening Method) 2017
11	Calcium mg/L	58.3	75	200	IS 3025 (Part 40):2019
12	Magnesium mg/L	18.5	30	100	IS 3025 (Part 46):2019
13	Color (Hazen)	1	5	15	APHA 23 rd Edition Color 2120 B (Visual Comparison Method)
14	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5): 2018

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 10 days (in case of non-perishable items only) from the date of issue of tests reports.

Authorized Signatory:
(Ankur Dixit)
Testing Lab In charge

Laboratory Contact details

Email- ankur.dixit452@gmail.com

Mob-8318782511

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO.074

Dated:- 15/06/2025

It is certified that an inspection team headed by Ram mani Shukla (Health officer)(Name of Officers with designation) from Health officer(Name of Department/ Office) inspected the INNOVATIVE MINDS ACADEMY, FAIZABAD(Name & Address of the school) on I.M.A (Date ofinspection) and found that the INNOVATIVE MINDS ACADEMY, FAIZABAD

(Name of school) has safe drinking water facilities for the students and members of staff of the intuition and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for period of 15/06/2025 - 15/06/2026

Signature with seal:

Name: Ram mani Shukla

Designation:

Name Address of the Office/Department Nagar Nigam Ayodhya

To

INNOVATIVE MINDS ACADEMYFaizabad .224001 (U.P)

(Name Address of the Institution)